



जिला जल जाँच प्रयोगशाला
लोक स्वास्थ्य प्रमंडल, औरंगाबाद
निर्गत सं०.....
तिथि.....

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Md. Shami Akhtar Executive Engineer, (Name of Officer with designation) from PHED P.H. Division Aurangabad. (Name of Department/Office) inspected Adani International School Mirzapur Aurangabad. (Name and Address of the School) on 14.06.2025 (Date of Inspection) and found that the Adani International School Mirzapur Aurangabad. (Name of School) has safe drinking water facilities for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of Two years.


All Tested parameters are in permissible range.

Shailend
17.06.25

Chemist
P.H. Div. Aurangabad

Chemist
P.H Division
Aurangabad


Assistant Engineer
P.H. Div. Aurangabad
Technical Manager
Com
Assistant Engineer
P.H. Division, Aurangabad


Signature with Seal.....
Name.....
Designation.....
Name & Address of the office.....

Quality Manager
Cum
Executive Engineer
P.H. Division, Aurangabad.

To
Adani International School
Mirzapur Behind Rishiap Police station
Aurangabad 824101.



Government of Bihar

District Level Water Testing Laboratory

P.H. Division, Aurangabad

जिला जल जांच प्रयोगशाला
लोक सार्वभौम प्रसन्न, औरंगाबाद
निर्गत सं०...../5744.....
दि०.....25/06/2025

District Name:- Aurangabad

Online Entry No:- U697368S30006090

Sample Submitted in Lab on date:- 14.06.2025
Date of Performance:- 14.06.2025 to 17.06.2025

Sample Collected by:- Self

S. N.	Block	Panchayat	Location of source	Chemical Parameters													
				p.H	Tur	EC	TDS	TH	Ca	Mg	ALK	Cl	Fe	SO ₄	F	T. Coli.	
1	Kutumba	Bharandha	Adani international School Mirjapur Aurangabad	7.14	0.83	585	380	230	48.00	26.67	328	15.98	0.32	12	0.64	-VE	
Acceptable Limit (IS 10500:2012)				6.50	1	-	500m g/l	200m g/l	75 mg/l	30 mg/l	200 mg/l	250 mg/l	1 mg/l	200 mg/l	1.0 mg/l	<1.1	
Maximum Permissible Limit in absence of alternate source				8.50	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	600 mg/l	1000 mg/l	NR	400 mg/l	1.5 mg/l	NR	
Remarks:- All Tested Parameters are in permissible range.																	

P.H. Division Aurangabad

Chemist

Shailendra
17.06.25

Chemist
P.H Division
Aurangabad

Assistant Engineer

P.H. Division Aurangabad
Technical Manager
Cum

Assistant Engineer
P.H. Division, Aurangabad

Executive Engineer

P.H. Division Aurangabad
Quality Manager
Cum

Executive Engineer
P.H Division