



District Name:-Aurangabad

Government of Bihar District Level Water Testing Laboratory

P.H.Division, Aurangabad

Sample Collected by:- Self

Sample Submitted in Lab on Date:- 30.06.2026

Date of performance:- 30.06.2026 to 02.07.2026

रजिस्ट्रार ऑफ़ प्रोडक्ट, औरंगाबाद
निर्गत सं०...112...
दि०...3/7/2026...

Month S.No	Block	Panchayat	Village	Location of Source	Chemical Parameters											
					pH	Turbidity	Electrical Conductivity	Total Dissolve Solid	Total Hardness	Calcium	Magnesium	Chloride	Total Alkalinity	Sulphate	Fluoride	Total Coliform
206	Kutumba	Bharaudha	Mirzapur	ADANI INTERNATIONAL SCHOOL Mirzapur Aurangabad	7.11	0.51	610	396	224	50.32	23.91	36.36	324	57	0.84	-ve
	Acceptable Limit (IS 10500:2012)				6.50	1NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	200 mg/l	1.00 mg/l	<1.1
	Maximum Permissible Limit in absence of alteranate source				8.50	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	400 mg/l	1.50 mg/l	NR

इस विद्यालय का जल जाँच प्रत्येक छह माह पर करना सुनिश्चित करें।

Shailendra
Chemist
P.H.Division, Aurangabad

P.H.Division
Chemist
Aurangabad

Assistant Engineer
P.H.Division, Aurangabad

Assistant Engineer
P.H.Division, Aurangabad

Executive Engineer
P.H.Division, Aurangabad

Executive Engineer
P.H.Division, Aurangabad



PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

कार्यपालक अभियंता
प. ह. खांछ प्रगंडल, औरंगाबादे
निर्गत सं०...../12.....
तिथि...21.7/2026.....

It is certified that an inspection team headed by Mr. Dharmendra Kumar Anand Executive Engineer.(Name of Officer with designation) from PHED P.H. Division Aurangabad (Name of Department/Office) inspected the Adani International school Mirzapur Aurangabad Bihar , (Name and Address of the School) on 30.06.2026 (Date of Inspection) and found that the ADANI INTERNATIONAL SCHOOL Mirzapur Aurangabad Bihar, (Name of School) has safe drinking water facilities for the student and members of staff of the institution and maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period of Six months.

*All tested parameter are
in permissible limit.*

Shailendra
02.07.26

Chemist
P.H. Div. Aurangabad

Chemist
P.H Division
Aurangabad

[Signature]
Assistant Engineer
P.H. Div. Aurangabad
Technical Manager
Com
Assistant Engineer
P.H. Division. Aurangabad

Signature with Seal:

Name

Designation

Name & Address of the office/ Department

[Signature]
Quality Manager
Executive Engineer
P.H Division, Aurangabad.